



# North Dakota Department of Transportation

Grant Levi, P.E.  
*Director*

Jack Dalrymple  
*Governor*

October 1, 2015

## ADDENDUM 3 – JOB 30

TO: All prospective bidders on project IM-8-029(165)063, Job No. 30, scheduled for the October 9, 2015 bid opening.

The following plan revision shall be made:

Plan Revision:

**Remove and replace sheet 6-2 with the enclosed sheet revised 9/30/2015.**

Sheet 6-2:

Note 770-P02 MULTIPLE UNDERGROUND CABLE has been added.

This addendum is to be incorporated into the bidder's proposal for this project.

CAL J. GENDREAU – CONSTRUCTION SERVICES ENGINEER

80:dch

Enclosure

STATE	PROJECT NO.	SECTION NO.	SHEET NO.
ND	IM-8-029(165)063	6	2

**NOTES**

**SECTION 140**

770-P01 REVISE LIGHTING: The overhead sign lighting for the sign structure at Sta 17+68 shall be operational before winter. All high mast lights affected by the slide repair shall be operational during winter.

770-P02 MULTIPLE UNDERGROUND CABLE: The plans call for using Multiple Underground Cable and Conduit in various locations. In lieu of the Multiple Underground Cable, the contractor may furnish and install rigid conduit and single RHW conductors of the same size as shown in the plans for the Multiple Underground Cable.

The conduit size shall be as specified in the National Electric Code. If the contractor chooses to use the conduit and single conductors, the cost to furnish conduit and conductors shall be included in the item Multiple Underground Cable. The cost of installing conduit with single conductors shall be included in the bid price for the "Revise Lighting System".

The conduit shown in the plans under roadways for installing Multiple Underground Cable will be included in the item "Revise Lighting System"

This document was originally issued and sealed by Blaine D. Johanneson, Registration Number PE-5038, on 09/30/15 and the original document is stored at the North Dakota Department of Transportation.